

COMMUNITY DEVELOPMENT SERVICES

ENVIRONMENTAL MANAGEMENT DEPARTMENT

http://www.edcgov.us/EMD/

PLACERVILLE OFFICE:

2850 Fairlane Court Placerville, CA 95667 (530) 621-5300 (530) 642-1531 Fax LAKE TAHOE OFFICE: 924 B Emerald Bay Rd. South Lake Tahoe, CA 96150 (530) 573-3450 (530) 542-3364 Fax

November 28, 2017

Grays Corner Water System Gurinderpal Gill, Owner 5 Nadia Joy Court Sacramento, CA 95834

RE: GRAYS CORNER WATER SYSTEM (PWS NO. 0900107) CITATION NO. 01_39_17C_008_0900107_03

Enclosed is the County of El Dorado, Environmental Management Local Primacy Agency Citation No. 01_39_17C_008_0900107_03 issued to Grays Corner Water System. Please note there are certain deadlines associated with this Citation.

Any person who is aggrieved by a citation issued by the El Dorado County LPA may file a petition with the State Water Resources Control Board (State Water Board) for reconsideration of the citation. Petitions must be received by the State Water Board within 30 calendar days of the issuance of the citation. The date of issuance is the date when the El Dorado County LPA mails or serves a copy of the citation, whichever occurs first. If the 30th day falls on a Saturday, Sunday, or state holiday, the petition is due the following business day. Petitions must be received by 5:00 p.m. Information regarding filing petitions may be found at:

http://www.waterboards.ca.gov/drinking water/programs/petitions/index.shtml

If you have any questions, please contact Jeffrey Warren at (530) 621-7628 or by email jeffrey.warren@edcgov.us, or Bryan Vyverberg at (530) 621-5924 or by email bryan.vyverberg@edcgov.us.

Sincerely,

Jeffre Marren, REHS

Environmental Health Program Manager

Cc: Ali Rezvani, PE

Enc.

1	EL DORADO COUNTY		
2	COMMUNITY DEVELOPMENT SERVICES		
3	ENVIRONMENTAL MANAGEMENT DEPARTMENT		
4			
5	TO: GRAYS MART AND GAS		
6	5 NADIA JOY COURT		
7	SACRAMENTO, CA 95834		
8	ATTN: GURINDERPAL GILL, OWNER		
9			
10			
11	CITATION FOR VIOLATION OF TITLE 22, CALIFORNIA CODE OF REGULATIONS		
12	SECTION(s) 64432, 64432.1(a), 64432.1(b)		
13	WATER SYSTEM NO: 0900107		
14	CITATION NO: 01_39_17C_008_0900107_03		
15	ISSUE DATE: 11/28/2017		
16	Section 116650 of the California Health and Safety Code authorizes the issuance of a		
17	citation to a public water system for failure to comply with a requirement of the California		
18	Safe Drinking Water Act, California Health and Safety Code, Division 104, Part 12,		
19	Chapter 4, commencing with Section 116270 (hereinafter "California SDWA"), or any		
20	regulation, standard, permit or order issued or adopted thereunder.		
21	The County of El Dorado Community Development Services, Environmental		
22	Management Department (hereinafter "Department"), hereby issues a citation to the		
23	GRAYS CORNER WATER SYSTEM (5 Nadia Joy Court; Sacramento, CA 95834) for		
24	violation of Title 22 of the California Code of Regulations ("CCR"), Sections 64432,		
25	64432.1 subsection (a), and 64432.1 subsection (b).		

Page 1 of 12

CITATION NO: 01_39_17C_008_0900107_03

APPLICABLE AUTHORITIES

Section 116275 of the California Health and Safety code provides in part:

- (b) "Department" means the state board.
- (ab) "State board" means the State Water Resources Control Board.

Section 116271 (k)(2) of the California Health and Safety Code states:

(k)(2) The deputy director is delegated the State Water Resources Control Board's authority to provide notice, approve notice content, approve emergency notification plans, and take other action pursuant to Article 5 (commencing with Section 116450), to issue, renew, reissue, revise, amend, or deny any public water system permits pursuant to Article 7 (commencing with Section 116525), to suspend or revoke any public water system permit pursuant to Article 8 (commencing with Section 116625) and to issue citations, assess penalties, or issue orders pursuant to Article 9 (commencing with Section 116650).

Section 116650 of California Health and Safety Code provides:

(a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed

Page 2 of 12

CITATION NO: 01_39_17C_008_0900107_03

1	refuses to accept delivery of the certified mail, the date of service shall be
2	deemed to be the date of mailing.
3	(b) Each citation shall be in writing and shall describe the nature of the violation
4	or violations, including a reference to the statutory provision, standard, order,
5	citation, permit, or regulation alleged to have been violated.
6	(c) A citation may specify a date for elimination or correction of the condition
7	constituting the violation.
8	(d) A citation may include the assessment of a penalty as specified in subdivision
9	(e).
10	(e) The department may assess a penalty in an amount not to exceed one
11	thousand dollars (\$1,000) per day for each day that a violation occurred, and for
12	each day that a violation continues to occur. A separate penalty may be
13	assessed for each violation.
14	California Code of Regulations, Title 22, Section 64431 (Maximum Contaminant
15	Levels – Inorganic Chemicals) states in relevant part:
16	Public water systems shall comply with the primary MCLs in table 64431-A as specified
17	in this article.
18	
19	Table 64431-A
20 21	Maximum Contaminant Levels Inorganic Chemicals

 Chemical
 Maximum Contaminant Level, mg/L

 Aluminum
 1.

 Antimony
 0.006

 Arsenic
 0.010

 Asbestos
 7 MFL*

Page 3 of 12

CITATION NO: 01_39_17C_008_0900107_03

Barium	1.
Beryllium	0.004
Cadmium	0.005
Chromium	0.05
Cyanide	0.15
Fluoride	2.0
Mercury	0.002
Nickel	0.1
Nitrate (as nitrogen)	10.
Nitrate+Nitrite (sum as nitrogen)	10.
Nitrite (as nitrogen)	1.
Perchlorate	0.006
Selenium	0.05
Thallium	0.002

2

3

5

7

6

8

9

10

11 12

4

A.

*MFL = million fibers per liter; MCL for fibers exceeding 10 µm in length.

California Code of Regulations, Title 22, Section 64432 (Monitoring and **Compliance – Inorganic Chemicals) states in relevant part:**

- (a) All public water systems shall monitor to determine compliance with the nitrate and nitrite MCLs in table 64431-A, pursuant to subsections (d) through (f) and Section 64432.1.
- (d) For the purposes of sections 64432, 64432.1, 64432.2, and 64432.3, detection shall be defined by the detection limits for purposes of reporting (DLRs) in table 64432-

Table 64432-A Detection Limits for Purposes of Reporting (DLRs) for Regulated Inorganic Chemicals

Chemical	Detection Limit for Purposes of Reporting (DLR) (mg/L)
Aluminum	0.05
Antimony	0.006
Arsenic	0.002
Asbestos	0.2 MFL>10um*
Barium	0.1
Beryllium	0.001
Cadmium	0.001
Chromium	0.01
Cyanide	0.1
Fluoride	0.1
Mercury	0.001
Nickel	0.01
Nitrate (as nitrogen)	0.4
Nitrite (as nitrogen)	0.4
Perchlorate	0.004
Selenium	0.005
Thallium	0.001

^{*} MFL=million fibers per liter; DLR for fibers exceeding 10 um in length.

- (e) Samples shall be collected from each water source or a supplier may collect a minimum of one sample at every entry point to the distribution system which is representative of each source after treatment. The system shall collect each sample at the same sampling site, unless a change is approved by the State Board.
- (f) A water system may request approval from the State Board to composite samples from up to five sampling sites, provided that the number of sites to be composited is less than the ratio of the MCL to the DLR. Approval will be based on a review of three years of historical data, well construction and aquifer information for groundwater, and intake location, similarity of sources, and watershed characteristics for surface water. Compositing shall be done in the laboratory.

1	California Code of Regulations, Title 22, Section 64432.1 – subsection (b) states in
2	relevant part:
3	
4	(b) All public water systems shall monitor to determine compliance with the MCL
5	for nitrite in Table 64431-A, by taking one sample at each sampling site during
6	the compliance period beginning January 1, 1993.
7	(1) If the level of nitrite in a single sample is greater than the MCL, the water
8	supplier shall proceed as for nitrate in accordance with paragraph (a)(1) of
9	this section.
LO	(2) The repeat monitoring frequency for systems with an analytical result for
l1	nitrite that is greater than or equal to 50 percent of the MCL shall be
12	quarterly monitoring for at least one year. After four consecutive quarterly
L3	samples are less than the MCL, a system may request that the State
L4	Board reduce monitoring frequency to annual sampling, collecting
15	subsequent samples during the quarter which previously resulted in the
16	highest analytical results.
L7	(3) The repeat monitoring frequency for systems with an analytical result for
18	nitrite that is less than 50 percent of the MCL shall be one sample during
19	each compliance period (every three years).
20	Local Primacy Delegation Agreement, Section 1.02. The Department hereby
21	delegates to the County all authority granted to it under the California Safe Drinking
22	Water Act (CHSC 116270) for regulation of small public water systems.
23	

1	STATEMENT OF FACTS		
2			
3	The GRAYS CORNER WATER SYSTEM (System) is operated under Domestic Water		
4	Supply Permit Number 0900107, issued by the El Dorado County Environmental		
5	Management Department on February 12, 2010.		
6	The System is a transient-noncommunity water system located in El Dorado County that		
7	supplies water to approximately 100 people per day for domestic purposes. The		
8	System operates all 365 days per year. The System is, according to Section 64432.1(a)		
9	of Title 22, required to collect one sample per year for analysis of Nitrate content to		
10	determine compliance with the MCL for nitrate. The System is, according to Section		
11	64432.1(b) of Title 22, required to collect one sample every three years for analysis of		
12	Nitrite content to determine compliance with the MCL for nitrite.		
13	In 2015 and 2016, the System failed to collect the minimum of one routine Nitrate		
14	sample from the groundwater well source in the water system. In 2015 and 2016, the		
15	System failed to collect the minimum of one routine Nitrite sample per compliance		
16	period from the groundwater well source in the water system. The last sample		
17	collection and testing for Nitrite from the well source in the water system was completed		
18	on July 29 th , 2011.		
19			
20	<u>DETERMINATIONS</u>		
21	Based on the Statement of Facts, the System failed to collect the minimum of one		
22	routine Nitrate sample per year and one Nitrite sample per compliance period from the		
	Page 8 of 12		

Issue Date: 11/28/2017

CITATION NO: 01_39_17C_008_0900107_03

1	groundwater well source in the system for the years 2015 and 2016. Consequently, the
2	Department has determined that the System violated Sections 64432, 64432.1(a), and
3	64432.1(b) of Title 22 of the California Code of Regulations for the years 2015 and
4	2016.
5	
6	DIRECTIVES
7	The System is hereby directed to take the following actions:
8	1. Comply with Sections 64432, 64432.1(a), and 64432.1(b) of Title 22 of the
9	California Code of Regulations in future monitoring periods.
10	
11	2. Within 30 days of issuance of this Citation, notify all persons served by the
12	System of the monitoring violations for nitrate and nitrite as required by
13	Section 64463.7, Title 22, of the California Code of Regulations.
14	Notification shall be completed in accordance with each of the following:
15	a. Posting the notification contained in Attachment "A" in conspicuous
16	locations throughout the area served by the water system.
17	b. Provide the notification contained in Attachment "A" by one or more
18	of the following methods to reach persons not likely to be reached
19	by the previous method:
20	i. Publication in a local newspaper or newsletter distributed to
21	persons served by the water system;
22	ii. Email notification message to employees:

Page 9 of 12

CITATION NO: 01_39_17C_008_0900107_03

1	iii. Posting on the internet;
2	iv. Direct delivery to each person served by the water system.
3	
4	3. Complete and return Attachment 'B' "Certification of Completion of Public
5	Notification" form within 10 days of giving public notice. A copy of the
6	notice used to provide public notification shall be attached to the form.
7	
8	4. Within 30 days of receipt of this Citation, the System shall submit a written
9	response to the Department indicating its willingness to comply with
LO	directives of this Citation.
l1 l2	
13	All submittals required by this Citation shall be submitted to the Department at the
L 4	following address:
15 16 17 18 19 20	Jeffrey Warren, REHS Environmental Management Program Manager El Dorado County Community Development Services Environmental Management Department 2850 Fairlane Ct., Building "C" Placerville, CA 95667
22	The Department reserves the right to make such modifications to this Citation as it may
23	deem necessary to protect public health and safety. Such modifications may be issued
24	as amendments to this Citation, and shall be deemed effective upon issuance.
25	

- Nothing in this Citation relieves Water System of its obligation to meet the requirements
- of the California Safe Drinking Water Act (SDWA), or of any regulation, permit, standard,
- 3 or order issued or adopted thereunder.

PARTIES BOUND

- 5 This Citation shall apply to and be binding upon the Grays Corner Water System, its
- officers, directors, shareholders, agents, employees, contractors, successors, and
- 7 assignees.

4

8

9

12

13

14

15

16

17

18

19

20

21

<u>SEVERABILITY</u>

- The directives of this Citation are severable, and the Grays Corner Water System shall
- comply with each and every provision thereof, notwithstanding the effectiveness of any
- 11 other provision.

FURTHER ENFORCEMENT ACTION

The California SDWA authorizes the Department to: issue citation with assessment of administrative penalties to a public water system for violation or continued violation of the requirements of the California SDWA or any permit, regulation, permit or order issued or adopted thereunder including, but not limited to, failure to correct a violation identified in a citation or compliance order. The California SDWA also authorizes the Department to take action to suspend or revoke a permit that has been issued to a public water system if the system has violated applicable law or regulations or has failed to comply with an order of the Department; and to petition the Superior Court to take various enforcement measures against a public water system that has failed to comply

Page 11 of 12

CITATION NO: 01_39_17C_008_0900107_03

1	with or violates an order of the Department. The Department does not waive any further		
2	enforcement action by issuance of this citation.		
3			
4	11/	28/2017	Molan
5	Date		Jeffrey Warren, REHS
6	Environmental Health Program Manager		
7 8	El Dorado County Community Development Services		
9			Environmental Management Department
10	Attachments:		
11		A. Tier 3 Monitoring Violations No	otice Template
12		B. Certification of Completion of I	•
13			
14 15	cc:	Ali R. Rezvani, P.E. Sacramento District Engineer	
16		Division of Drinking Water	
17		State Water Resources Control E	Board
18			